

% Compliance SANS 241:2015 new reporting of water quality July 2024 to June 2025										
Category	Laing	Sandile	Nahoon	Albany Coast	Debe	Peddie	Glenmore	Binfield	Masinedane	Overall Compliance
Acute Health Microbiological Compliance %	92.7	99.2	99	100	100	97.4	100	100	96.2	97.2
Acute Chemical Compliance	100	100	100	100	100	99.8	100	100	100	100
Chronic Chemical Compliance	98.8	100	100	99.6	98.7	96.9	100	100	100	99.1
Operational Compliance	85.1	90.5	97.8	97.5	79.1	96.4	98.5	98.1	85.6	91.9
Aesthetic Compliance	99.9	100	99.5	83.2	98.3	100	99.4	100	99.2	97.3
Average %	95.3	97.9	99.3	96.1	95.2	98.1	99.6	99.6	96.2	97.1
Population	172,600	121,500	185,000	16,000	17,200	81,500	5,000	43,800	13,500	656,100
Excellent										
Good										
Unacceptable										

Water Services Operations Manager

Date